

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 709	01-01-05	Candidate Number	
Skill Title: SHUTTING OFF LPG OR CNG SERVICE				
NFPA Objective:	5.3.18	Minimum to pass	4	
PERFORMANCE:				P F

	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Searches area/building for LPG or CNG cylinder or tank.				
	3.	Locates shut-off on cylinder or tank.				
	4.	Closes shut-off valve clockwise fully or in the direction of the arrow on the valve.				
	5.	Confirms to examiner the LPG or CNG service has been shut off.				